

## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. H.O./2025-26/396

Dated: 05/06/2025

It is certified that an inspection team headed by .Circle 11, Health Inspector.....

(Name of Officers with designation) from Nagar.Nigam, Ajmer.....PHED

inspected the **Maheshwari Public School, DP Choudhary Marg, Vaishali Nagar, Ajmer (305004) Raj.**

(Name & Address of the school) on ..02/06/2025.....(date of inspection) and on the basis of

Water Test Report (Attached) bearing no. Lab/Tech./2025-26/235..... dated..22/05/2025.....

of P.H.E.D. Regional Lab., Ajmer..... (PHED Lab) certified that

the **Maheshwari Public School, Vaishali Nagar, Ajmer.** ( Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till ...04/06/2026.....

Signature with Seal: .....

Name

Designation

Name & Address of the Office / Department : .....


To

**Maheshwari Public School**.....

**DP.Choudhary Marg, Vaishali Nagar, Ajmer**

**(Name & Address of the Institution)**

**Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies**

  
PRINCIPAL  
Maheshwari Public School  
AJMER

**OFFICE OF THE SUPERINTENDING CHEMIST**  
**PUBLIC HEALTH ENGINEERING DEPARTMENT REGIONAL LABORATORY, AJMER (Raj)**  
**REPORT OF THE CHEMICAL EXAMINATION OF WATER**

No. Lab/Tech./ 2025-26/ 235

Date: 22.5.2025

Sample was not Collected  
by Laboratory

To,  
Principal  
Maheshwari Public School  
Ajmer

District: AJMER  
Tehsil:- Ajmer

Not for Legal Purpose

Reference : Your Letter No.- Nil Dated 09.05.2025

Sample Collected by :- Rajesh Bhargav


Date of Receipt :- 09.05.2025

Lab Sample No.		IS10500:2012		P-12
Source :				R O Treated water
Source Location:				School Area Near New Building
Town / Village				Ajmer
Date of Collection→				09.05.2025
Date of Examination→				09.05.2025
Test Parameter↓				Results↓
1	pH Value	6.5 - 8.5	No Relaxation	7.38
2	Turbidity (NTU) Max	1	5	0.8
3	Colour (Hazen Units), Max	5	15	Nil
4	Odour	Agreable		Agreable
5	Total Alkalinity (as CaCO <sub>3</sub> ) mg/l, Max	200	600	130
6	Total Hardness (as CaCO <sub>3</sub> ) mg/l, Max	200	600	150
7	Chlorides as Cl <sup>-</sup> mg/l, Max	250	1000	60
8	Fluorides as F <sup>-</sup> mg/l, Max	1.0	1.5	0.4
9	Nitrate as NO <sub>3</sub> <sup>-</sup> mg/l, Max	45	No Relaxation	12
10	Total Dissolved Solids(T.D.S.) mg/l, Max	500	2000	392
11	Residual Chlorine	0.2	1.0	Nil
		Applicable only when water is Chlorinated		

Note: 1. The sample was not collected by this laboratory.

2. This Report is not for legal Purpose.

  
**PRINCIPAL**  
**Maheshwari Public School**  
**AJMER**

  
 (Dr. Archana Mathur)  
**Superintending Chemist**  
**P.H.E.D.Regional Lab.,Ajmer**